

A New Combined Bidirectional 84 Pulse (Multi Level + Multi Pulse) Converter With High-Frequency Link

Bhukya Jala *1 : Firoz Ali.Md 2 : Dr. Abdul Ahad3

1M.tech (P.E) Student Department Of EEE, Nimra College Of Engineering & Technology

2 Asst. Professor Department Of EEE, Nimra College Of Engineering & Technolog

3Professor & Head Of The Department, Nimra College Of Engineering & Technology

ABSTRACT: This paper analyzes the structure of an 84-pulse voltage source converter (VSC), assembled by combining one twelve-pulse VSC, in conjunction with an asymmetric single phase seven-level converter plus an injection transformer. With this arrangement, the VSC output's total harmonic distortion in voltages is reduced, allowing it to be used in especial applications or as the basement of flexible A.C. transmission systems (FACTS) devices. The proposed strategy allows savings in the number of employed switches. Simulations and experimental results are provided to show the proposal appropriateness.

I.INTRODUCTION: The Static Synchronous Compensator (StatCom) is one of the most useful FACTS devices, since it can synthesize the reactive power from small storing elements. When it is operated within the linear region, it is seen by the system as a synchronous voltage source. By regulation of the Statcom's output voltage magnitude, the reactive power exchange between the device and the transmission system may be controlled to improve the power system voltage profile. Since the StatCom may cause interference on the system's fundamental sine wave at frequencies that are multiples of the fundamental one, especial care should be taken to ensure not to pollute the system to prevent further harmonic issues. In general, there are three feasible strategies to assemble a VSC:

- (i) the multi-pulse;
- (ii) the multi-level;
- (iii) and the pulse width modulation (PWM).

Strong efforts have been made in order to reach minimum harmonic distortion in the VSC's output voltage. A strategy to build an 84-pulse equivalent output voltage waveform, which employs a twelve-pulse along with an eight-level reinjection converter is presented in [10]. However,

the cost for this is 26 extra switch devices and 7 DC voltage sources (capacitors).

This array makes the control task difficult because of the amount of gate signals needed, and it is prone to unbalance, due to the large chain of capacitors. Multi-Level Voltage Reinjection (MLVR) H-bridge conversion is another option to generate 84 pulses, which requires the use of 5 additional DC voltage sources and 12 switches, as opposed to the conventional 12-pulse converter. It may be easily utilized to attain more levels on the reinjection by adding H-bridges in series.

This paper describes a strategy to generate the 84-pulse VSC, assembled with the combination of one 12-pulse converter with a seven-level converter, as well as one reinjection transformer to attain the required performance. The extra components are: 8 switches, 4 DC voltage sources, and 4 diodes for the seven-level converter. A reinjection transformer is needed, which is able to work properly within a wide range of its turn ratio. This constitutes an attractive array in terms of costs. In high-voltage applications, the voltage will generally be higher than the switches' and diodes' ratings at the current technology. Therefore, each symbol in the following diagrams may represent a

chain of series-connected switches with auxiliary components.

II. 84-PULSE VSC TOPOLOGY

Numerous methods have been investigated to increase the number of pulses in the multi-pulse converters' output. The simplest one is by increasing the number of six-pulse converters and the corresponding transformers (4 six-pulses converter results in 24-pulse, 8 six-pulse converter results in 48-pulses operation, and so forth). The harmonic cancellation is carried out by the transformer secondary windings' arrangement. The weakness of this method is the large size and high cost due to the increased number of bridges and transformers. In order to overcome such difficulty, an auxiliary circuit in the DC link side has been proposed for reinjection [12]. Such topology results through modifying the DC input on the conventional double bridge twelve-pulses shunt converters through a multi-level auxiliary circuit with an injection transformer [13]. In this paper, an asymmetric 7-level array for the auxiliary circuit is used as a reinjection scheme, Fig. 1. The conventional double bridge twelve-pulse operation is assembled by connecting two identical three-phase bridges to three-phase transformers in a parallel VSC configuration. Each branch in the six-pulse converter must have a displacement of 120° among them. The upper switch is conducting while the lower one is open and vice versa (180° voltage source operation) [14]. A 30° displacement in then firing sequence of both converters should be considered. Transformer's turn ratios are 1:1 and 1: 3 on the YY and Y Δ transformers, respectively. By injecting additional DC pulses via the three-phase bridges' neutral point, an effect of pulse spreading is attained. The auxiliary circuit is common to the three phases, reducing the number of extra components. The configuration description to provide pulse multiplication is detailed in [9, 10, 12, 15, 16, 21]. In Fig. 1, A-B illustrates the auxiliary seven-level inverter utilized as a reinjection circuit. To apply the seven-level inverter output voltage to feed the standard twelve-pulse converter, special care should be taken to not inject negative voltage into YV or V $\square$; notice the inclusion of the injection transformer between both arrays.

Thus, voltages at the six-pulse converter inputs can be regulated by adjusting the injection voltage iU by:

$$V_Y = V_{DC} + U_i$$

$$V_\Delta = V_{DC} - U_i$$

The injection voltage is determined by the seven-level inverter switching pattern and the injection transformer turns ratio. By using voltages V_Y and V_Δ as inputs to the six-pulse converters, a cleaner VSC's output voltage comes about. Fig. 2 exhibits the followed strategy to build V_{YU} and $V_{\Delta U}$ as the interaction of the seven-level output and the corresponding six-pulse signals. Through the 1:1 ratio for the YY TRANSFORMER, 1: $\sqrt{3}$ for the Y Δ TRANSFORMER, and adding their corresponding output signals, the 84-pulse line-to-neutral signal V_U emerges (Fig. 3a). The corresponding harmonic spectrum is depicted in Fig. 3b, illustrated on a linear scale, while the one presented in Fig. 4 is displayed in decibels. V_U is an odd symmetric signal, so that the Fourier's even terms are zero.

III. SIX-PULSE GENERATOR

The second block is the six-pulse generator, responsible for generating the pulse sequence to fire the three-phase IGBT array. It consists of an array of six-pulse spaced 60° each other. The IGBT will operate at full 180° for the *on* period and 180° for the *off* period. Any disturbance on the frequency will be captured by the synchronizing block, preventing malfunctioning. The falling border in the synchronizing block output signal is added to a series of six 60° spaced signals.

The modulus operator with the 2π argument gives the needed *on* sequence that will be sent to the gate opto-coupler block, which will feed each six-pulse converter. The *off* sequence turns out on a similar way but waiting 180° to keep the same *on* and *off* duration in each IGBT.

IV. SEVEN-LEVEL PULSE GENERATOR

To operate the seven-level inverter, six times the frequency of the six-pulse generator must be ensured. This is achieved by monitoring the falling border in the novel PLL output signal, using it along with the modulus operator with the $\pi/3$ argument. This signal will be the period for the seven-level generator which will change its state each $\pi/42$ rad.




Fig.1 simulation of 84 pulse custom power device

$$V_U(t) = \sum_{n=1}^{\infty} V_{U,2n-1} \sin((2n-1)\omega t)$$

$$V_{U,2n-1} = \frac{4V}{3\pi(2n-1)} (A_{2n-1} + aB_{2n-1})$$

$$A_{2n-1} = 2 + 2 \cos\left(\frac{1}{3}\pi(2n-1)\right) + 2\sqrt{3} \cos\left(\frac{1}{6}\pi(2n-1)\right)$$

$$B_{2n-1} = \sum_{i=0}^{20} \text{Coeff}_i \cos\left(\frac{i}{42}\pi(2n-1)\right)$$

where

$$\text{Coeff} = \begin{Bmatrix} -3, & 1, & 1, & 1, & 1, & 1, & 1, \dots \\ -3\sqrt{3}, & \sqrt{3}-1, & \sqrt{3}-1, & \sqrt{3}-1, & \sqrt{3}-1, & \sqrt{3}-1, & \sqrt{3}-1, \dots \\ -3, & -\sqrt{3}+2, & -\sqrt{3}+2, & -\sqrt{3}+2, & -\sqrt{3}+2, & -\sqrt{3}+2, & -\sqrt{3}+2, \dots \end{Bmatrix}$$

In (4), a is the reinjection transformer turns ratio.




fig. 2 mixing seven-level, six-pulse signals, and transformer's ratios to attain V_{nu} and $V_{\Delta U}$.





fig. 3(a) 84-pulse line-to-neutral output voltage



(b) harmonic content

The 84-pulse signal value (V_U) depends on the injection transformer turns ratio a , which is determined so as to minimize the total harmonic distortion (THD), which is defined by [9, 17]:

$$THD_{VU} = \sqrt{\frac{\sum_{n=2}^{\infty} V_{Un}^2}{V_{U1}^2}} \quad (7)$$

The minimization of THD yields the parameter a . In this paper such estimation has been made through MATLAB for a value $n = 7200$, with increments of $a = 0.0001$. With these parameters, the minimum THD becomes 2.358% with $a = 0.5609$, value employed in previous figures. According to the IEEE Std. 519, the distortion limits indicate that the allowed THD voltage is 10% in dedicated systems, 5% in general systems, and 3% for special applications as hospitals and airports [17]. Table 1 presents the voltage's minimum THD generated by several multi-pulse configurations. Through our proposition, the resultant THD allows its use even in applications with stringent quality requirements; it exhibits less

dependence to variations in the transformer's turn ratio a , which can have a variation until $\pm 12.5\%$ to reach a maximum THD lower than 3%. This means that it does not need a strict reinjection transformer turn ratio in order to get the THD for stringent conditions.

Table 1 Minimum THD reached through VSC multi-pulses-based

Number of pulses	THD (%)
12	15.22
24	7.38
48	3.8
60	3.159
84	2.358

CONCLUSION

This paper describes the strategy to obtain an 84-pulse VSC three-phase voltage with the associated low THD, by combining one twelve-pulse converter plus a seven-level converter.

The device performance, proven on a lab prototype, allows to verify the harmonic content of the resultant voltage signal. The exhibited low THD, permits the system to be used in especial applications or as basement of FACTS devices. The three-phase digital PLL used to detect the phase of the fundamental voltage, synchronizes the firing signals in all switches within a sample cycle.

REFERENCES

- [1] Hingorani, N. G.: "FACTS Technology – State of the Art, Current Challenges and the Future Prospects," *IEEE Power Engineering Society General Meeting*, 24-28 June 2007, Tampa, Florida USA
- [2] Song, Y. H., and Johns, A. T.: 'Flexible AC transmission systems FACTS,' (IEE Power and Energy Series 30, 1999)
- [3] Acha, E., Fuerte-Esquivel, C. R., Ambriz, H., Angeles, C.: 'FACTS. Modelling and Simulation in Power Networks.' (John Wiley and Sons, LTD, 2004.)

[4] Wang, H. F.: "Applications of damping torque analysis to StatCom control", *Electrical Power and Energy Systems*, Vol. 22, 2000, pp. 197- 204.

[5] CIGRE, "Static Synchronous Compensator", *CIGRE working group 14.19*, September 1998.

[6] Hingorani, N. G., and Gyugyi, L.: 'Understanding FACTS,' (IEEE Press 2000).

[7] El-Moursi, M. S., and Sharaf, A. M.: "Novel Controllers for the 48-Pulse VSC StatCom and SSSC for Voltage Regulation and Reactive Power Compensation", *IEEE Transactions on Power Systems*, Vol. 20, No. 4, November 2005, pp. 1985-1997.

BIBLIOGRAPHY

Bhukya jala : pursuing M.Tech in Nimra College of engineering and technology, Jupudi, Ibrahimpatnam. His specialization in power electronics. He graduated in Electrical and Electronics Engineering from lakky reddy and bali reddy college of engineering, Mylavaram, Mail id jala.ram212@gmail.com

Firozali Mohammed: is currently working as an ASSOCIATE PROFESSOR in Electrical and Electronics Engineering department at Nimra College of engineering and technology (NCET) Jupudi, Ibrahimpatnam he obtained his M TECH degree in power Electronics from Satyabhama university, Chennai. He received B.Tech degree in Electrical and Electronics Engineering from NCET, VIJAYAWADA. His research interest includes power Electronics converters and applications Mail id firozalimd1@gmail.com

DR.Abdul Ahad : Mtech. P.hd (NITK) is an eminent PROFESSOR & HEAD OF EEE , nimra group of colleges. he received M.Tech and was conferred Doctorate from NITK SURATKAL. He is expertised in power electronics, power systems, special machines, Electrical machines& industrial applications. He has over a 15 years of teaching experience .He trains various students for various competitive exams like IES ,IAS, GATE , AP GENCO,AP TRANSCO, DISCOMS and no of national competitive exams. He is the chair person of several national and technical symposiums. He published more than 20 international journals and attended several international conferences. His prime interest is in research .to his credit he guided scores of UG AND PG students in their projects and right now he is guiding two P,hd

